

G-M WATER SUPPLY CORPORATION
PO BOX 727
HEMPHILL, TX 75948
409-787-2755

Dear Customer,

The Texas Commission on Environmental Quality (TCEQ) has notified the G-M WSC TX2020067 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/l) based on locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter three 2015 of 0.099 mg/l for DBP2-04 and 0.093 mg/l for DBP2-01.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing HAA5 in excess of the MCL **over many years** may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

G-M Water Supply Corporation is addressing this issue. We are making changes to our process control. Introducing a coagulant in the Clarifier reducing the Free Chlorine dosage to the Raw water and increasing the Chloramine Treatment after Filtration along with increased monitoring.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Vance C. Hoyle, Jr at 409-787-2755.

Posted/Delivered on: 10-8-15